

## 质量证书

### Quality Certificate

产品名称 Product Name		VCC A500		
生产批号 Production Batch		JJ320231113	规格 Specification	透明/300ml Clear/300ml
检测依据 Testing criterion		JC/T 485-2007《建筑窗用弹性密封胶》 JC/T 485-2007 Elastic sealant for building windows		
序号 No.	检验项目 Test Item	指标 Indicator	检验结果 Testing Result	单项判定 Individual Evaluation
1	外观 Appearance	不应有结块、凝胶、结皮及不易迅速均匀分散的析出物 No lumps, gels, and crusts that are not easy to disperse quickly and evenly	无结块、凝胶、结皮及不易迅速均匀分散的析出物 No lumps, gels, and crusts that are not easy to disperse quickly and evenly	合格 Pass
2	挤出性, mL/min Extrudability	$\geq 150$	605	合格 Pass
3	表干时间, min Tack-free time	$\leq 120$	8	合格 Pass
4	下垂度, mm Slump	$\leq 3$	0	合格 Pass
5	最大拉伸强度 Tensile strength, MPa	$\geq 0.4$	0.46	合格 Pass
	此处空白 Blank			
结论 Result	产品经检验, 所检项目符合 JC/T 485-2007《建筑窗用弹性密封胶》标准规定的 SR3 MCG A K 要求。 以下空白 Sample Tested, and the inspected items meet the requirements of SR3 MCG A K specified in the JC/T 485-2007 "Elastic Sealant for Building Window" standard. The following is blank.			
备注 Comment	检验结果仅对本公司生产产品负责。 The inspection results are only responsible for the products produced by the company.			
主检: Inspected by:		审核: Examined by:		批准: Approved by:

检验单位章

Testing center seal

签发日期: 二〇二三年十一月二十二日

Sign and Issue date: 22/11/2023

本报告结束